



CITY OF MONTE SERENO

18041 SARATOGA-LOS GATOS ROAD, MONTE SERENO, CA 95030
(408) 354-7635 • FAX (408) 395-7653 • WWW.CITYOFMONTESERENO.ORG

RESIDENTIAL BATHROOM REMODEL

BUILDING DIVISION REQUIREMENTS

A permit is required for bathroom remodels that include the replacement of the tub/shower enclosure. A permit is not required for replacement of plumbing fixtures (sink or toilet) in the same location. If a permit is required, it shall be obtained prior to the start of the remodel.

Following is a listing of the general requirements based on the 2019 California Building Code, 2019 California Residential Code, 2019 California Electrical Code, 2019 California Plumbing Code, 2019 California Green Building Standards (CalGreen), and 2019 California Energy Efficiency Standards. This brochure is intended to provide general information, contact the Building Department for any questions or additional information.

Tub/Shower Requirements

- The mixing valve in a shower (including over a tub) shall be pressure balancing set at a maximum 120° F. The water-filler valve in bathtubs/whirlpools shall have a temperature limiting device set at a maximum of 120° F. The water heater thermostat cannot be used to meet these provisions. (CPC 408.3, 409.4)
- New or reconfigured shower stalls shall be a minimum finished interior of 1,024 square inches, be capable of encompassing a 30 inch diameter circle. Any doors shall swing out of the enclosure have a clear opening of 22 inches minimum. (CPC 408.5, 408.6)
- Shower stalls and bathtubs with shower heads installed, shall have walls finished with a non-absorbent surface for a minimum of 6 feet above the floor. (CBC 1209 and CRC R307.2)
- Hydro-massage tubs (i.e. Jacuzzi tubs) shall have access to the motor, be supplied by a GFCI protected dedicated circuit, and be listed by a recognized testing agency (i.e. UL). All metal cables, fittings, piping, or other metal surfaces, within 5 feet of the inside wall of the Hydro-massage tub shall be properly bonded. Hydro-massage tubs shall be bonded with a minimum #8 AWG bare copper wire and the bonding shall be accessible. (CEC 680.70)
- Underlayment material used as backers for wall tile or solid surface material in tub and shower enclosures shall be either glass-mat/fiber-reinforced gypsum backing panels (i.e. DensShield, Dens Armor Plus), non-asbestos fiber-cement/fiber mat back board (i.e. Hardibacker, cement board). All material shall be installed in accordance with the manufacturer's recommendations.

Water-resistant gypsum board (i.e. purple board) may be used when attached directly to studs, overlaid with minimum Grade B building paper and wire lath. Tile shall be attached to the wire lath. (CBC 2509 and CRC R702.4)

- Shower floors shall be lined with an approved shower pan or an on-site built watertight approved lining (i.e. hot mop). On-site built shower linings shall extend a minimum of 3 inches vertically up the wall and shall be sloped $\frac{1}{4}$ " per foot to weep holes. (CPC 408.7)
- When a curb is provided at a shower, it shall be a minimum of 1 inch above the shower floor and between 2 inches and 9 inches above the top of the drain. A watertight nailing flange that extends a minimum of 1 inch high shall be installed where the shower floor meets the vertical surface of the shower compartment. The finished floor of the shower compartment shall be uniformly sloped between $\frac{1}{8}$ " and $\frac{1}{2}$ " per foot towards to the drain. (CPC 408.5)

Where a curb is not provided at the shower compartment, the entire bathroom shall be considered a wet location. The flooring in the entire bathroom shall comply with the water proofing requirements described above for shower floors (previous bullet) and all lighting fixtures shall be approved for wet locations.

Water Closet Requirements

- The water closet shall have a clearance of 30 inches wide (15 inches on center) and 24 inches in front. (CPC 402.5)
- Where the water closet (or other plumbing fixture) comes into contact with the wall or floor, the joint shall be caulked and sealed to be watertight. (CPC 402.2)

Tempered Glazing (CBC 2406.4, 2403.1 and CRC 308.1, R308.4)

Tempered glazing shall be installed in the locations listed below. Tempered glazing shall be permanently identified by a manufacturer marking that is permanently applied and cannot be removed without being destroyed (e.g. sand blasted, acid etched, ceramic fired, laser etched, or embossed).

- Within a portion of wall enclosing a tub/shower where the bottom exposed edge of the glazing is less than 60 inches above the standing surface and drain inlet.
- Within 60 inches of a tub/shower where the glazing is less than 60 inches above the walking surface.
- Glazing within 24 inches of either side of the door in the plane of the door in a closed position.
- Glazing on the hinge-side of an in-swinging door that is installed perpendicular to a door in a closed position and within 24 inches of the door.

Electrical and Lighting Requirements

- All receptacles shall be GFCI protected and tamper-resistant (TR). If any new/additional outlets are installed, the bathroom shall have a dedicated 20-amp circuit. (CEC 210.8, 210.11, 406.12)
- Exhaust fans with a minimum ventilation rate of 50 CFM are required in all bathrooms, even if an operable window is installed. Exhaust fans and lighting shall have separate control switches (even

if a combination unit is installed). The exhaust fan may need to be supplied by a GFCI protected circuit based on the manufacturer’s requirements. (CEES 150.0(k), 150.0(o))

- Lighting fixtures located within 3 feet horizontally and 8 feet vertically of the bathtub rim or shower stall threshold shall be listed for a damp location, or listed for wet locations where subject to shower spray. (CEC 410.10)
- Receptacles exceeding 20 amperes in a wet location shall have an enclosure that is weatherproof when the attachment plug is removed. (CEC 406.9(B)2)
- Receptacles shall not be installed within or directly over a bathtub or shower stall. (CEC 406.9(C))
- All installed lighting fixtures shall be high efficiency.

At least one light fixture shall be controlled by a vacancy sensor switch that requires a manual on activation (does not automatically turn on) and automatically turns off within 30 minutes after the room is vacated. All other light fixtures shall be controlled by a vacancy sensor or dimmer.

All light fixtures shall contain bulbs that are labeled as JA8-2019 (JA8-2019-E for sealed lens or recessed fixture). Screw base bulbs are permitted, except in recessed lighting fixtures.

Recessed lighting shall be listed as IC (zero clearance to insulation) and AT (air tight), be sealed/caulked between the fixture housing and ceiling, shall not contain a screw base socket, and contain bulbs marked with JA8-2019-E efficiency label. (CEES 150.0(k))

Water Efficient Plumbing Fixtures (CalGreen 301.1.1, 4.303)

Residential buildings undergoing permitted alterations, additions, or remodels are required to replace all non-compliant plumbing fixtures (based on water efficiency) throughout the house with water-conserving plumbing fixtures. The following table shows what is considered to be a non-compliant plumbing fixture and the current water efficiency standards for various plumbing fixtures. All existing non-compliant plumbing fixtures shall be replaced with fixtures meeting the current standards.

Plumbing Fixture	Non-Complaint Plumbing Fixture	Current Standard for the Maximum Flow Rate of Newly Installed Plumbing Fixtures
Water Closet (Toilet)	Greater than 1.6 gallons/flush	1.28 gallons/flush
Showerhead	Greater than 2.5 gallons/minute	1.8 gallons/minute at 80 psi
Faucet - Bathroom	Greater than 2.2 gallons/minute	1.2 gallons/minute at 60 psi
Faucet - Kitchen	Greater than 2.2 gallons/minute	1.8 gallons/minute at 60 psi (average)

Residential building constructed after January 1, 1994 are exempt from this requirement.

Smoke and Carbon Monoxide Alarms (CBC 907.2.10, CRC 314 and 315)

Smoke alarms shall be installed on the ceiling or wall (between 4” and 12” of the ceiling) in all sleeping rooms, each area/hallway adjacent to sleeping rooms, each story of the building, and in any basement. Smoke alarms shall be replaced 10 years after the date of manufacture listed on the alarm (if no date is listed the alarm shall be replaced). Newly installed smoke alarms shall have a 10-year battery.

Carbon monoxide (CO) alarms shall be installed on the ceiling or wall (above the door header) in each area/hallway adjacent to sleeping rooms, each occupiable story, and within a bedroom if the bedroom or attached bathroom contains a fuel-burning appliance. CO alarms are not required if there is no fuel-burning appliance or fireplace in the house and where the garage is detached from the house.

PERMIT PROCESS

Building Permit Review

1. Permit can be submitted at City Hall between 9am and 5pm Monday through Friday.

Inspections

The number of inspections required depends on the type of underlayment used in the tub/shower enclosure and the scope of the project. Following are the minimum inspections required, information about additional required inspections can be provided when the building permit is issued.

2. A rough plumbing and electrical inspection should be scheduled for the tub/shower valve and electrical wiring prior to installation of any wallboard.
3. The next inspections scheduled should be for the underlayment and the shower pan test, if applicable.
4. Fire inspections shall be completed prior to rough inspection and final inspection.
5. The final inspection should be scheduled after all the work is completed.

**Building Permit Application Requirements
(3 copies of each item)**

- A completed Building Permit Application
- A floor plan showing the existing and proposed conditions, including any affected load-bearing walls.